


NOTES:

1. REMOVE JUMPER JA TO PREVENT HANDSWITCH INITIATED MOTION
2. J1 AND J2 ARE REQUIRED AS SHOWN
3. 240VAC ALARM AVAILABLE BETWEEN TERMINALS B AND E.



17-5509-100 C

SIZE:
A

THIS DOCUMENT IS A COPY AND IS NOT THE SOURCE DOCUMENT. INFORMATION IS SUBJECT TO CHANGE WITHOUT NOTICE. THE INFORMATION CONTAINED HEREIN IS COPYRIGHTED BY HAROLD BECK AND SONS, INC. CHANGES TO THE DOCUMENT ARE PROHIBITED. CONTACT A BECK SALES ENGINEER IF A CERTIFIED DRAWING IS REQUIRED.

HAROLD BECK & SONS INC

NEWTOWN INDUSTRIAL COMMONS NEWTOWN, PENNSYLVANIA 18940 USA

TITLE:
WIRING DIAGRAM GROUP 11-1X9/2X9/3X9/409/419/469
240 VOLT 0 AUX SWITCHES INT CPS
W/ HART/LOCAL DCM

DRAWN: CHH 10-12-07	SCALE: NONE	DRAWING NO: 17-5509-100	REV: C
CHECKED: GMD 10/15/07		SHEET NO. 1 OF 1	
APPROVED: JHM 10/16/07			